



Water

Do not drink, prepare food or wash with tap water until officials say the water source is safe. Contact your water provider or check their website for up-to-date information. Use bottled water until you hear differently from your water system operator.

The delay in more information is due to needing to test the water for volatile organic compounds (VOC). These occur when plastic piping heats up to a high degree. At this higher temperature, the pipes can release benzenes or other harmful chemicals or gases.

Water Operators

| | |
|-----------------------------|--------------|
| HILAND WC - BEAR CREEK | 503-554-8333 |
| HILAND WC - BOULDER CREEK | 503-554-8333 |
| HILAND WC - ECHO MOUNTAIN | 503-554-8333 |
| HILAND WC - RIVERBEND | 503-554-8333 |
| ANTONIOS BAR AND GRILL | 541-961-4993 |
| GUPTIL SUBDIVISION | 542-921-3777 |
| LINCOLN CITY KOA | 541-994-2961 |
| OTIS JUNCTION WATER SYSTEM | 541-996-4844 |
| PANTHER CREEK WD | 541-994-7293 |
| SALMON RIVER MOBILE VILLAGE | 541-994-3893 |
| SALMON RIVER RV PARK | 541-994-3116 |
| WESTWIND STEWARDSHIP GROUP | 541-994-2383 |

Wells

If you have your own well and are not on a community water system, check to make sure there has been no damage. You can visually check for:

- Damaged and melted or exposed electrical wiring,
- Damaged and melted PVC casing, liner or pipes,
- Damaged well houses and pressure tanks,
- Debris such as ash and sediment entering uncovered wells,
- Old dug wells with wood covers, which can become a safety threat.

Exposed electrical wiring to the well are a significant electrical safety hazard with the potential for an electrical short to the metal casing.

- If the electrical wiring has been damaged, do not handle the wiring or touch the casing.
- Flag the area around the well casing as a warning.

Dug wells or septic systems with covers may have been damaged by fire and are a significant hazard to public safety.

- The well cover or septic systems with a cover may be damaged to such an extent that it may drop into the well or septic tank can be so unstable that walking on it may cause a collapse.
- If you discover what appears to be a sinkhole or open hole, flag or barricade the area around it.

If your well has been damaged by fire, or you think an old dug well has been exposed, contact a local licensed and bonded well constructor or pump installer to determine the extent of the damages and what must be done to either repair or decommission the well.

If you think a fire may have damaged your water supply, use bottled water until you are sure it is safe. The general rule is that each person will need at least one gallon of water per day for drinking, cooking and hygiene.

If your septic system has been damaged by fire, contact Lincoln County Planning Department and a local licensed and bonded septic installer to determine the extent of the damages and what must be done to either repair or decommission the septic system.

Lincoln County Emergency Call Center – 541-265-0621

Extensions:

- 1 - English COVID
- 2 - Spanish COVID
- 3 - Echo Mtn Fire Resources Info (voice recording of how to access FEMA/Red Cross/Donations will be in Spanish and English)
- 4 - x4192 Planning Department
- 5 - x4171 Solid Waste Department
- 6 - x0458 Environmental Health
- 7 - x4179 Behavioral Health
- 8 - x4102 Assessors Office
- 9 - x4100 Board of Commissioners
- 10 - x0616 Emergency Management (all other inquiries)